

STANDARD INFORMATION

This SUN establishes the superseding of ANSI/ISA 12.12.01 and introduces ANSI/UL 121201 as the superseding standard

Superseded Standard Number: ANSI/ISA 12.12.01

Superseded Standard Name: Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Superseding Standard Number: UL 121201

Superseding Standard Name: Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Standard Edition and Issue Date: 9th Edition Dated September 15, 2017

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **June 30, 2020**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revise requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revise requirements.

Standard ANSI/ISA 12.12.01 has been superseded by UL 121201. As a result, manufacturers must start transitioning their reports from ISA 12.12.01 to the harmonized standard UL 121201 / CSA C22.2 No. 213:2017.

After **June 30, 2020**, unless superseded by further SUN notices, UL 121201 / CSA C22.2#213:2017 or newer editions apply to all previously certified Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Location.

Special consideration if being given to NFPA 1801 Standard on Thermal Imagers for Fire Safety.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.