

STANDARD INFORMATION

Standard Number: ANSI Z21.21 / CSA 6.5

Standard Name: Automatic Valves for Gas Appliances

Standard Edition and Issue Date: 6th Edition dated June 1, 2019

Date of Revision: June 1, 2019

Date of Previous Revision of Standard: 5th Edition dated July 1, 2015

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **June 1, 2021**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revise requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revise requirements.

Overview of Changes: Additional markings for C/I valves. Specific details of new/revise requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revise paragraphs noted in the attached or explain why these new/revise requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
4	Info	Construction
4.10	Info	Marking
		<i>New clause added;</i>
4.10.3		When electrically operated valves with C/I Marking consisting of two individually packaged assemblies, a valve (body) and coil, are shipped for subsequent assembly by the end user, each section of the valve shall be marked with the following or equivalent statement "Section of assembly consisting of Part No. xxxx body and Part No. yyyy coil (or actuator)".
CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.		