

STANDARD INFORMATION

Standard: ASME A112.19.3 / CSA B45.4

Standard ID: Stainless Steel Plumbing Fixtures [ASME A112.19.3/CSA B45.4:2022 Ed.3]

Previous Standard ID: Stainless Steel Plumbing Fixtures [ASME A112.19.3/CSA B45.4:2017 Ed.2+E1;E2]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **August 1, 2024**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes:

- New requirements for use of different materials
- New requirements for flanges
- New requirements for supply fittings
- New requirements for wall-mounted fixtures

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
4	Info	General requirements
4.1	Info	General
		<i>New clause added;</i>
		Different materials
4.1.2		When a fixture is made of a combination of stainless steel and other materials covered under ASME A112.19.1/CSA B45.2, ASME A112.19.2/CSA B45.1, or CSA B45.5 / IAPMO Z124, the other materials shall comply with the applicable requirements of those same standards.
4.8	Info	Additional requirements for bathtubs and shower bases
4.8.3	Info	Flanges
		<i>New clause added;</i>
4.8.3.2		Shower bases intended for installation against and securing to a wall shall incorporate a continuously raised flange at least 25 mm (1.0 in) above the threshold and comply with Clauses 4.8.3.3 to 4.8.3.5.
		<i>New clause added;</i>
4.8.3.5		The bottom of any hole in the flange or corner treatment shall be not less than 8 mm (0.3 in) above the rim or threshold.
		<i>New clause added;</i>
4.8.4		Supply fittings
		Factory-supplied supply fittings shall comply with ASME A112.18.1/CSA B125.1.
6	Info	Markings, packaging, and installation instructions and other literature
6.5	Info	Packaging and installation instructions and other literature
6.5.3	Info	Installation instructions
6.5.3.1	Info	General
		<i>New clause added;</i>
		Wall-mounted fixtures
6.5.3.1.3		Wall-mounted fixtures shall include instructions for proper installation of the fixtures and minimum structural support requirements.