

STANDARD INFORMATION

Amendment 1: See updated Effective Date in blue below.

Standard: CSA C22.2 No. 113

Standard ID: Fans and Ventilators [CSA C22.2#113:2018 Ed.11]

Previous Standard ID: Fans and Ventilators [CSA C22.2#113:2015 Ed.10+U1]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: ~~January 1, 2023~~ January 1, 2024

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard.

Currently certified products to CSA C22.2 No. 113 that are now covered under CSA C22.2 No. 60335-2-80 or CSA E60335-2-31 shall comply with CSA C22.2 No. 60335-1 and the applicable part 2 standard by the effective date.

- **Products such as ceiling fans, desk or table fans, hassock fans, suitcase or “box” fans, pedestal fans, agricultural fans, partition fans, duct fans, and window fans that are within the scope of CSA C22.2 No. 60335-2-80 are no longer covered in the scope of this standard.**
- **Range hoods that are within the scope of CSA C22.2 No. E60335-2-31 are no longer covered in the scope of this standard.**
- **Fans other than those described above will remain certified to CSA C22.2 No. 113; the updates to the standard as shown in the table below must be applied.**

Overview of Changes from CSA C22.2 No. 113 10th edition to CSA C22.2 No. 113 11th edition:

- Revised scope of standard
- Additional requirements for temperature test
- Revised requirements for lint test

Specific details of new/updated requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
		The following changes reflect the changes between CSA C22.2 No. 113-15 and CSA C22.2. No 113-18
1	Info	Scope <i>New clause added;</i>
1.4		This Standard does not apply to products that are within the scope of CAN/CSA-C22.2 No. 60335-2-80, such as ceiling fans, desk or table fans, hassock fans, suitcase or “box” fans, pedestal fans, agricultural fans, partition fans, and duct fans. <i>New clause added;</i>
1.5		This Standard does not apply to range hoods that are within the scope of standard CAN/CSA-C22.2 No. E60335-2-31.
12	Info	Clothes dryer booster fans (or dryer exhaust duct power ventilators (DEDPVs))
12.3	Info	Markings
12.3.3	Info	Instruction manual
12.3.3.3		The wording “READ AND SAVE THESE INSTRUCTIONS” and “LIRE AND CONSERVER CES INSTRUCTIONS” shall appear in the installation and operating instructions.
12.4	Info	Tests
12.4.8	Info	Lint test
12.4.8.3	Info	The clothes dryer duct shall terminate in a lint trap measuring 305 mm (12 in) wide, 305 mm (12 in) long, and 305 mm (12 in) high. The lint trap construction shall consist of a frame made of 9.5 mm (3/8 in) square wooden dowels wrapped in 0.25 mm ± 0.02 mm <u>0.3 mm ± 0.05 mm (0.0118 ± 0.0019 in)</u> diameter wire steel mesh with 0.8 mm (0.03 in) square openings. One side of the lint trap shall include the male end of the duct connector mounted to 9.5 mm (0.375 in) plywood. <i>NOTE: This change does not require retesting of currently-certified products.</i>