

STANDARD INFORMATION

Addendum 1: This addendum includes additional requirements that were previously missed in an earlier revision. These requirements are below in blue font.

Standard Number: CSA C22.2 No 230

Standard Name: Tray Cables

Standard Edition and Issue Date: 3rd Edition Dated March 1, 2017

Date of Revision: February 1, 2014 and March 1, 2017

Date of Previous Revision of Standard: January 1, 2014

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: November 10, 2018

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revised requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revised requirements.

Overview of Changes: Clause 6.2.1.2 has been revised to state that the “TC-ER” marking requires additional tests over and above the “TC” marking alone. Specific details of new/revised requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action Required:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
		The revision dated February 1, 2014 was issued to incorporate the following:
4	Info	Construction
4.2		<u>Single conductor constructions shall not be smaller than 1/0 AWG.</u>
		The revision dated March 1, 2017 was issued to incorporate the following:
6	Info	Marking
6.2	Info	Product markings
6.2.1	Info	Product markings (mandatory)
6.2.1.2		Cables shall be marked with the letters "TC" <u>for cables complying with Clauses 5.1, 5.2, 5.3, 5.4.1, 5.5.1 and 5.6 or "TC-ER" for cables complying with Clauses 5.1, 5.2, 5.3, 5.4.1, 5.4.2, 5.5.2 and 5.6.</u>
		CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.