

## STANDARD INFORMATION

**Standard Number:** CSA C22.2 No. 269.4

**Standard Name:** Surge Protective Devices - Type 4 - Component Assemblies

**Standard Edition and Issue Date:** 2<sup>nd</sup> Edition Dated March 1, 2017

**Date of Revision:** March 1, 2017

**Date of Previous Revision of Standard:** 1<sup>st</sup> Edition Dated November 1, 2014

## EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

**Effective Date:** **November 30, 2018**

## IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** A review of all Listing Reports is necessary to determine which products comply with new/revise requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revise requirements.

**Overview of Changes:** Added a requirement for an operating instruction that requires Type 4 SPDs be installed by qualified persons. Specific details of new/revise requirements are found in table below.

**If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).**

### **Client Action Required:**

**Information** – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revise paragraphs noted in the attached or explain why these new/revise requirements do not apply to your product (s).

***Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.***



## STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown <del>lined out</del> below.</i>
5	Info	<b>Documentation, ratings, and markings</b> <b><i>New clause added;</i></b>  The operating instructions required by Clause 5.1 shall include the following words:  “Type 4 SPDs shall only be installed by a qualified person”  5.13 And  « Les dispositifs de protection contre les surtensions de type 4 ne doivent être installés que par une personne qualifiée. »  or equivalent.
CUSTOMERS PLEASE NOTE: This Table and column “Verdict” can be used in determining how your current or future production is or will be in compliance with new/revised requirements.		