

STANDARD INFORMATION

Standard: CSA C22.2 No. 42

Standard ID: General Use Receptacles, Attachment Plugs, and Similar Wiring Devices [CSA C22.2#42:2010 Ed.7+U1;U2;U3;U4;U5]

Previous Standard ID: General Use Receptacles, Attachment Plugs, and Similar Wiring Devices (R2020) [CSA C22.2#42:2010 Ed.7+U1;U2;U3;U4]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **September 1, 2023**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes:

- Revisions to wiring devices incorporating components intended for surge suppression and/ or filtering of connected loads
- Additional requirements for receptacles

Specific details of new/ revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
5	Info	Construction
		Wiring devices incorporating components intended for surge suppression and/ or filtering of connected loads
5.9		Wiring devices incorporating components for surge suppression or filtering, or both, shall comply with the <u>applicable requirements of CSA C22.2 No. 1 and CSA C22.2 No. 8.</u> In addition, devices incorporating ac line connected varistors shall comply with the test requirements of Clause 8.34. <u>applicable requirements of CSA C22.2 No. 269.3.</u>
7	Info	Markings
7.1	Info	General
		<i>New clause added;</i>
7.1.10.1		For a receptacle in compliance with Clause 5.1.2.6, and where a terminal is used in accordance with Clause 5.1.7.3 c) and it is not readily visible or where the grounding terminal is readily removable, the area around the wire entrance hole shall be coloured green and be marked in letters at least 2 mm high adjacent to the wire entrance hole with GREEN, G, GR, GROUND, or with the symbol “ \perp ”.