

STANDARD INFORMATION

Standard Number: FM 3611

Standard Name: Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Standard Edition and Issue Date: 2018 Edition dated January 1, 2018

Date of Revision: December 1, 2016 and January 1, 2018

Date of Previous Revision of Standard: December 1, 2004

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **May 1, 2020**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revised requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revised requirements.

Overview of Changes: Addition of reference to ANSI/UL 121201. Specific details of new/revised requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
2	Info	GENERAL INFORMATION <i>New clause added;</i>
2.1		Marking Information In addition to the marking required for ordinary location equipment and ANSI/UL 121201, the equipment shall be marked in accordance with FM 3600.
		PERFORMANCE AND CONSTRUCTION REQUIREMENTS
3		<u>Except where modified by the requirements of this standard, nonincendive electrical equipment shall comply with the applicable requirements of ANSI/UL 121201.</u> Except where modified by the requirements of this standard, nonincendive electrical equipment shall comply with the applicable requirements for ordinary locations, in accordance with FM 3600.
CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.		