

STANDARD INFORMATION

This SUN establishes partial superseding of UL 1773 and introduces UL 1008 as the superseding standard

Standard Number: UL 1773

Standard Name: Termination Boxes

Standard Edition and Issue Date: 6th Edition Dated October 9, 2018

Date of Revision: October 9, 2018

Date of Previous Revision of Standard: April 29, 2016

Partial Superseding Standard Number: UL 1008

Partial Superseding Standard Name: Transfer Switch Equipment

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **November 14, 2020**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revised requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revised requirements.

The requirements for Inlet Assemblies for Transfer Switch Equipment were included as Annex J in the Standard for Transfer Switch Equipment, UL 1008, 8th edition revision dated December 22, 2014. This annex covers permanently installed inlet assemblies rated 600 V or less, which are intended to facilitate temporary connection of portable generators to transfer switches (for optional standby systems) through the use of single pole separable connectors. To prevent overlap and possible conflicts of requirements, a statement is added to the Scope of UL 1773 (reference clause 1.5(d)) identifying UL 1008, Annex J, as the source of requirements for Inlet Assemblies for Transfer Switch Equipment.

NOTE: As this change in the Standard scope will redirect products intended as Inlet Assemblies for Transfer Switch Equipment, existing Certifications will be reviewed. Impacted products will either be re-evaluated to UL 1008, Annex J, or have their Certifications withdrawn by the Effective Date.

Overview of Changes: Removal of inlet assemblies for transfer switch equipment. Specific details of new/revised requirements are found in table below.

- Removal of inlet assemblies for transfer switch equipment



If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
1	Info	Scope This standard specifically does not apply to: a) Equipment connected only by bus bars for both input and output circuits; b) Equipment containing switching devices, relays, or overcurrent protective devices; c) Busway fittings known as "End Cable Tap Boxes" which are covered by the Standard for Busways, UL 857; and 1.5 <u>d) Inlet assemblies for cord connection of generators used in conjunction with transfer switch equipment which are covered by the Standard for Transfer Switch Equipment, UL 1008, Annex J, Inlet Assemblies for Transfer Switch Equipment.</u> NOTE: As this change in the Standard scope will redirect products intended as Inlet Assemblies for Transfer Switch Equipment, existing Certifications will be reviewed. Impacted products will either be re-evaluated to UL 1008, Annex J, or have their Certifications withdrawn by the Effective Date.
CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.		