

Standard Information

Standard Number: UL 2021

Standard Name: Fixed and Location-Dedicated Electric Room Heaters

Standard Edition and Issue Date: 4th Edition Dated September 30, 2015

Date of Revision: December 14, 2016

Date of Previous Revision of Standard: 4th Edition Dated September 30, 2015

Effective Date of New/Revised Requirements

Effective Date: **November 9, 2018**

Impact, Overview, and Action Required

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revised requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revised requirements.

Overview of Changes: This revision includes requirements for Heating Elements. Specific details of new/revised requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action Required:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.

Description of New/Revised Technical Requirements

Clause	Verdict	Comment
16	Info	Heating Elements
16.1.1		A sheath type heating element shall comply with the requirements in: <ul style="list-style-type: none"> a) The Standard for Sheathed Heating Elements, UL 1030; or b) The Standard for Electric Heating Appliances, UL 499, except the minimum sheath thickness shall be 0.016 in. (0.33 mm).
		CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.