

## STANDARD INFORMATION

**Standard:** UL 2075

**Standard ID:** Gas and Vapor Detectors and Sensors [UL 2075:2013 Ed.2+R:31Aug2021]

**Previous Standard ID:** Gas and Vapor Detectors and Sensors [UL 2075:2013 Ed.2+R:21Dec2017]

## EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

**Effective Date:** **February 1, 2025**

## IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

**Overview of Changes:** One Year Sensor Stability Test for Gas Sensors. Specific details of new/updated requirements are found in table below.

***Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.***



## STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown <del>lined-out</del> below.</i>
33	Info	<b>Stability Tests</b> <i><b>New section added;</b></i>  <b>One Year (minimum) Sensor Stability Test for Gas Sensors</b>
33.4		A minimum fifteen samples of the gas sensor shall be placed within a closed chamber (test fixture) that shall allow for the following:  See standard for details.