

STANDARD INFORMATION

This SUN establishes the Continuing Certification approach for Aboveground Reinforced Thermosetting Resin Conduit and Fittings

Standard Number: UL 2515 / CSA C22.2 No. 2515

Standard Name: Aboveground Reinforced Thermosetting Resin Conduit (RTRC) and Fittings

Standard Edition and Issue Date: 2nd Edition dated February 5, 2019

Date of Revision: February 5, 2019

Date of Previous Revision of Standard: 1st Edition revised January 2014

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **No action is required for currently certified products to maintain certification.**

This SUN is being presented to assist users of the standard to appreciate the significance of the changes made to the standard that will apply should the product described be modified after June 1, 2020

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Effective immediately, this revised standard will be exclusively used for evaluation of new products. A Future SUN may require all products be certified to the most recent version of the standard.

Overview of Changes:

- Removal of carbon-arc testing
- Update the FT4 Procedure in Wire and Cable Test Methods

Specific details of new/revised requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required) if and when you make any changes to your product.

Client Action:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).



Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.

STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
5	Info	Qualification tests
5.11	Info	Vertical flame test (FT4) – conduit on cable tray (optional)
5.11.8	Info	Propane
5.11.8.1		The gas supplied to the burner shall be natural grade propane meeting the requirements of CAN/CGSB 3.14 (Grade 1) and having a heat equivalent of approximately 46.4 MJ/kg (85.0 MJ/m³ at 20°C, 101 kPa) at a minimum 95% purity, <u>having a heating value of 94 ±2 MJ/m³ (2540 ±50 Btu/ft³).</u>
5.14		<i>This new edition removed the use of carbon-arc testing. All testing using carbon-arc apparatus will need to be re-evaluated using xenon-arc testing.</i>
CUSTOMERS PLEASE NOTE: This Table and column “Verdict” can be used in determining how your current or future production is or will be in compliance with new/revised requirements.		