

STANDARD INFORMATION

Standard: UL 414

Standard ID: Metered Sockets [UL 414:2016 Ed.9+R:22Jun2022]

Previous Standard ID: Metered Sockets [UL 414:2016 Ed.9+R:14Dec2020]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **June 22, 2024**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Addition of meter socket adapters for use with distributed generation equipment. Specific details of new/revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>New supplement added;</i>
		METER SOCKET ADAPTERS FOR USE WITH DISTRIBUTED GENERATION EQUIPMENT
		These requirements cover meter socket adapters intended for use with distributed generation equipment, including energy generating and energy storage equipment.
Supplement SB		These requirements cover meter socket adapters with provisions for connection of interactive equipment to the main circuit in addition to the blades and jaws of the meter socket adapter.
		These requirements cover meter socket adapters that have components associated with distributed generation sources, with no provisions for connections to the main circuit other than through the blades and jaws of the meter socket adapter.
		See standard for details.