

STANDARD INFORMATION

Standard: UL 48

Standard ID: Electric Signs [UL 48:2011 Ed.15+R:16Mar2021]

Previous Standard ID: Electric Signs [UL 48:2011 Ed.15+R:07Dec2018]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **March 16, 2023**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard.

Overview of Changes:

- Switch not serving as sign disconnect
- Accessibility of through wiring

Specific details of new/ revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
4	Info	Construction
4.2	Info	Electrical
4.2.2	Info	Accessibility to live parts
4.2.2.1		General
		<i>New clause added;</i>
4.2.2.1.6		An integral raceway or compartment provided to allow branch circuit(s) or feeder conductor(s) to pass through a sign body or enclosure without supplying any circuits of the sign shall be constructed such that the through wiring will not become accessible during sign servicing.
7	Info	Marking
7.1	Info	General
		<i>New clause added;</i>
7.1.7		A switch provided with the sign that is not intended to serve as the sign disconnect switch shall have a marking provided adjacent to the switch indicating “NOT A DISCONNECT”.
		<i>New clause added;</i>
7.1.8		The marking required in 7.1.7 shall be located next to the switch on an external surface of the sign where visible after installation.
8	Info	Instructions
8.1	Info	General
		<i>New clause added;</i>
8.1.8		The following statement or its equivalent shall be included in the installation instructions, or provided on a separate sheet or tag shipped with a permanently connected sign: “The location of the disconnect switch after installation shall comply with Article 600 of the National Electrical Code.”