

STANDARD INFORMATION

Standard: UL 514D / CSA C22.2 No 42.1

Standard ID:

Cover Plates for Flush-Mounted Wiring Devices [UL 514D:2013 Ed.2+R:15May2020]

Cover Plates for Flush-Mounted Wiring Devices [CSA C22.2#42.1:2013 Ed.2+U1;U2]

Previous Standard ID:

Cover Plates for Flush-Mounted Wiring Devices [UL 514D:2013 Ed.2+R:04Mar2016]

Cover Plates for Flush-Mounted Wiring Devices [CSA C22.2#42.1:2013 Ed.2+G1]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **May 15, 2022**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard.

Overview of Changes: Revision to illuminating cover plates for flush-mounted wiring devices for Canada only. Specific details of new/revise requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
Annex B	Info	Illuminating Cover Plates For Flush-Mounted Wiring Devices
B.3	Info	Construction <i>New clause added;</i> Canada, electrical connection to branch circuit shall comply with the following: B.3.5 a) Field wiring terminals, push-in connections or supply conductors – See B.2.4; or b) Plug blades to attach to an outlet box mounted receptacle. The blade portion of the device shall comply with the blade dimensions specified in Wiring Devices – Dimensional Specifications, ANSI/NEMA WD 6. In the United States, this requirement does not apply.
B.3.6		<i>New clause added;</i> In Canada, constructions, including spring-biased contacts, that make electrical connection with the heads of wiring device wire binding screws are NOT permitted. In the United States, this requirement does not apply.