

STANDARD INFORMATION

Standard: UL 795

Standard ID: Commercial-Industrial Gas Heating Equipment [UL 795:2016 Ed.8+R:01Sep2020]

Previous Standard ID: Commercial-Industrial Gas Heating Equipment [UL 795:2016 Ed.8]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **September 1, 2022**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard.

Overview of Changes: Changes in requirements for gas vent valve and lines. Specific details of new/updated requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
	Info	CONSTRUCTION – BURNER ASSEMBLIES
26	Info	General
		<i>New clause added;</i>
26.9		<p>Burners having a maximum firing rate per combustion chamber in excess of 12,500,000 Btu per hour and equipped to fire fuel gas having a specific gravity less than one shall also include a normally open 3/4 inch (19.1 mm) or larger electrically-operated valve in a vent line located between the two safety shutoff valves.</p> <p>Exception: If an automatic valve proving system performs a valve proving system sequence on both safety shutoff valves during each burner cycle and functions to prevent light-off in the event of a detectable leak, a normally open vent valve is not required to be used.</p>