

STANDARD INFORMATION

Standard Number: UL 962A
Standard Name: Furniture Power Distribution Units
Standard Edition and Issue Date: 5th Edition dated June 12, 2018
Date of Revision: April 23, 2019
Date of Previous Revision of Standard: July 13, 2018

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **April 23, 2021**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revise requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revise requirements.

Overview of Changes: This revision for UL 962A includes the New Supplement SC – Furniture Power Distribution Units for Kitchen and Bathroom Countertops. Specific details of new/revise requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revise paragraphs noted in the attached or explain why these new/revise requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i>
		<i>New supplement added;</i>
		Furniture Power Distribution Units for Kitchen and Bathroom Countertops
Supplement SC		These requirements cover indoor use only cord and plug connected, furniture power distribution unit (FPDU's) for a kitchen or bathroom countertops. A FPDU for a kitchen or bathroom countertop is intended for connection to a permanently-installed receptacle on a branch circuit rated 125 V AC and 20 Amperes or less. A FPDU for a kitchen or bathroom countertop is intended for mounting to either a portable or stationary furnishings only, as a power supply connection for cord and plug connected electrical utilization equipment, in accordance with the National Electrical Code, NFPA 70 (see standard for details).
		CUSTOMERS PLEASE NOTE: This Table and column "Verdict" can be used in determining how your current or future production is or will be in compliance with new/revised requirements.