

STANDARD INFORMATION

Standard Number: ULC S652

Standard Name: Standard for Tank Assemblies for the Collection, Storage and Removal of Used Oil

Standard Edition and Issue Date: 3rd Edition Issued February 1, 2016

Date of Revision: February 1, 2016

Date of Previous Revision of Standard: May 1, 2008

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **February 14, 2019**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: A review of all Listing Reports is necessary to determine which products comply with new/revised requirements and which products will require re-evaluation. **NOTE:** Effective immediately, this revised standard will be exclusively used for evaluation of new products unless the Applicant requests in writing that current requirements be used along with their understanding that their listings will be withdrawn on Effective Date noted above, unless the product is found to comply with new/revised requirements.

Overview of Changes: Revised the marking section. Specific details of new/revised requirements are found in table below.

If the applicable requirements noted in the table are not described in your report(s), these requirements will need to be confirmed as met and added to your report(s) such as markings, instructions, test results, etc. (as required).

Client Action Required:

Information – To assist our Engineer with review of your Listing Reports, please submit technical information in response to the new/revised paragraphs noted in the attached or explain why these new/revised requirements do not apply to your product (s).

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
<p><i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined out below.</i></p>		
6	Info	<p>MARKING</p> <p><i>New clause added;</i></p>
6.1		<p>Appendix A contains safety related markings and warnings that are required to be in English and French. In addition some Canadian provincial/territorial authorities may require other markings to be in either or both official languages (English and French).</p>
6.2		<p>The following information shall be engraved or stamped on a corrosion resistant nameplate permanently attached to the tank and located so as to be readily visible when installed:</p> <p>A Name of tank manufacturer; B “USED OIL TANK ASSEMBLY”; C Year of manufacture; D Metal thickness, mm; E Maximum operating pressure, 7 kPa; F Maximum operating vacuum, 300 Pa; G Emergency venting capacity, m³/min; H Nominal capacity, L; and <u>I Standard number, e.g. CAN/ULC-S652.</u></p>
6.4		<p>The following statements shall be stencilled on each tank <u>Each tank shall be clearly marked, with materials that are resistant to the environment to which the tank is intended to be exposed, with the following information</u> in letters of not less than 10 mm in height in a contrasting colour:</p> <p>A “FOR USED OIL ONLY – NOT FOR FLAMMABLE LIQUIDS” (located at the receptacle); B “DO NOT LIFT OR TRANSPORT TANK CONTAINING PRODUCT” (located at each lift lug or fork lift channel); and C “CONSULT THE INSTALLATION INSTRUCTIONS OF THE MANUFACTURER AND WITH THE AUTHORITY HAVING JURISDICTION AND THE INSTALLATION <u>INSTRUCTIONS PRIOR TO INSTALLATION”.</u></p>
<p>CUSTOMERS PLEASE NOTE: This Table and column “Verdict” can be used in determining how your current or future production is or will be in compliance with new/revised requirements.</p>		